

Exploring the Benefits of Monitoring-based Commissioning

Michael J. Dooley, PE, CCP, CEM, LEED AP

Partner, Commissioning, AKF

AIA Quality Assurance



The Building Commissioning Association is a Registered Provider with The American Institute of Architects Continuing Education Systems (AIA/CES). Credit(s) earned on completion of this program will be reported to AIA/CES for AIA members. Certificates of the Completion for both AIA members and non-AIA members are available upon request.

This program is registered with AIA/CES for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product.

Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.

Course Description


Explore the advantages of Monitoring-Based Commissioning (MBCx) and its impact on compliance, safety, operations, and energy consumption. MBCx is a continuous commissioning process that utilizes advanced analytics and real-time monitoring to optimize building performance. MBCx provides many advantages, such as improving indoor air quality, reducing energy costs, and enhancing safety and security. By continuously monitoring critical parameters and analyzing data, MBCx enables facility managers to identify areas for improvement and implement targeted energy efficiency and sustainability strategies. Monitoring-based commissioning analytics provide feedback so systems can be tuned to use as little energy as possible without compromising occupant comfort. As a result, facilities can achieve substantial cost savings while reducing their carbon footprint, contributing to sustainability goals. Real-time monitoring also allows facility managers to proactively adjust and monitor temperature fluctuations, air exchange rates, and filtration efficiency to improve functionality, efficiency, and overall performance. As technology advances, MBCx will play a significant role in shaping the future of design, construction, and operation.

Learning Objectives

1. Describe the principles of MBCx and how it can improve building performance.
2. Identify the key components of an MBCx system and how they work together to optimize building performance.
3. Evaluate the benefits of MBCx.
4. Analyze case studies of successful MBCx implementations and the lessons learned.


What is Commissioning?

A quality-focused process for enhancing the delivery of a project. The process focuses upon verifying and documenting that the facility and all its systems and assemblies are planned, designed, installed, tested, operated, and maintained to meet the Owner's Project Requirements.




Commissioning Process

- Traditional New Construction Cx
- Retro-Commissioning/Existing Building Commissioning
- Ongoing Cx
- Monitoring-Based Cx



ASHRAE Guideline 0-2019
(Supersedes ASHRAE Guideline 0-2013)
Includes ASHRAE addenda listed in Appendix Q

The Commissioning Process



THIRD EDITION



New Construction Commissioning Process

Commissioning Process ASHRAE Guideline 0



- Process
- Building Types
- Types of Commissioning
- Building Turnover

Existing Building Commissioning Process

- Re-Commissioning
- Retro-Commissioning
- Ongoing Commissioning
- Monitoring-Based Commissioning
- Standards/Guidelines
- Never Been Commissioned



ASHRAE Guideline 1.2-2019

**Technical Requirements for
the Commissioning Process
for Existing HVAC&R
Systems and Assemblies**



**THE BUILDING
COMMISSIONING
HANDBOOK**

THIRD EDITION



Monitoring Based Commissioning (MBCx)

- This is not just BMS
- Software Driven
- Empirical live data
- Prioritization & Tuning is Critical
- Automated Process



Key Elements of a MBCx Program

PHYSICAL

- Permanent Energy Monitoring
- Energy Management and Information System (EMIS) Software
- Fault Detection and Diagnostics
- Dashboards – Key Performance Indicators


PROCESS

- Current Facility Requirements
- Monitoring Action Plan
- Preventative Maintenance and Calibration
- Measurement and Verification





Manual Ongoing Cx vs MBCx


Valve feedback.c...						
Search						
File Home Insert Draw Page Layout Formulas Data Review View Automate Help PDF-XChange						
Clipboard Font Alignment Number Styles Cells						
E10 : X ✓ fx 09-Jan-18 3:21:50 PM EST						
A	B	C	D	E	F	G
	PECO_MOB_Chil lPlant/ChillerPla nt V-1_Feedback (%)		PECO_MOB_ChilPl ant/ChillerPlant V- 2_Feedback (%)		PECO_MOB_Chill Plant/ChillerPlan t nviCTBypassVlv1	
1 ?Timestamp		?Timestamp		?Timestamp		?Timestamp
2 30-Oct-18 8:35:00 PM EDT	0.2	01-Jan-18 12:00:00 AM EST	17	03-Jan-18 12:10:57 PM EST	0	01-Jan-18 12:00:04 AM
3 30-Oct-18 8:40:00 PM EDT	0.2	01-Jan-18 12:15:00 AM EST	25	03-Jan-18 12:10:57 PM EST	100	01-Jan-18 12:00:09 AM
4 30-Oct-18 8:45:01 PM EDT	0.2	01-Jan-18 12:30:00 AM EST	20	03-Jan-18 12:11:05 PM EST	100	01-Jan-18 12:00:26 AM
5 30-Oct-18 8:50:00 PM EDT	0.2	01-Jan-18 12:45:00 AM EST	24	03-Jan-18 12:11:05 PM EST	0	01-Jan-18 12:01:06 AM
6 30-Oct-18 8:55:00 PM EDT	0.2	01-Jan-18 1:00:00 AM EST	22	03-Jan-18 12:11:38 PM EST	10	01-Jan-18 12:01:58 AM
7 30-Oct-18 9:00:01 PM EDT	0.2	01-Jan-18 1:15:00 AM EST	23	03-Jan-18 12:12:10 PM EST	0	01-Jan-18 12:02:15 AM
8 30-Oct-18 9:05:00 PM EDT	0.2	01-Jan-18 1:30:00 AM EST	21	09-Jan-18 3:21:04 PM EST	30	01-Jan-18 12:03:34 AM
9 30-Oct-18 9:10:00 PM EDT	0.2	01-Jan-18 1:45:00 AM EST	22	09-Jan-18 3:21:18 PM EST	20	01-Jan-18 12:04:55 AM
10 30-Oct-18 9:15:01 PM EDT	0.2	01-Jan-18 2:00:00 AM EST	16	09-Jan-18 3:21:50 PM EST	30	01-Jan-18 12:06:13 AM
1 30-Oct-18 9:20:00 PM EDT	0.2	01-Jan-18 2:15:00 AM EST	20	09-Jan-18 3:23:30 PM EST	28.5	01-Jan-18 12:07:30 AM
2 30-Oct-18 9:25:00 PM EDT	0.2	01-Jan-18 2:30:00 AM EST	18	09-Jan-18 3:23:36 PM EST	25.7	01-Jan-18 12:08:45 AM
3 30-Oct-18 9:30:01 PM EDT	0.2	01-Jan-18 2:45:00 AM EST	16	09-Jan-18 3:23:42 PM EST	23.2	01-Jan-18 12:08:56 AM
4 30-Oct-18 9:35:00 PM EDT	0.2	01-Jan-18 3:00:00 AM EST	18	09-Jan-18 3:23:48 PM EST	20.5	01-Jan-18 12:09:18 AM
5 30-Oct-18 9:40:00 PM EDT	0.2	01-Jan-18 3:15:00 AM EST	23	09-Jan-18 3:23:54 PM EST	18.1	01-Jan-18 12:10:21 AM
6 30-Oct-18 9:45:01 PM EDT	0.2	01-Jan-18 3:30:00 AM EST	18	09-Jan-18 3:24:00 PM EST	15.6	01-Jan-18 12:11:26 AM



Application of MBCx



Safety Classification – Air Changes per Hour



- Engage
- Define
- Prove

Figure 2 Risks associated with airborne hazards and the levels of protection associated with the range of LVDLs.


Performance: *Air Quality – Compliance*

- AHJ-ACH, Pressurization (NIH, AAALAC) BSL3
- Compounding Pharmacy – USP 800, FGI
- Design to installation to verification (ACH and pressure relationships)
- Initial verification relies on instrumentation measurement.
- Ongoing verification requires sensors to maintain calibration.
- Smart air quality sensing system (ie Aircuity).




Centralized Indoor Air Quality System

- Dynamic Airflow Control
- Lowest Energy Consumption
- Air Quality to Meet Occupant Needs
- Not Perfect




Performance – Indoor Air Quality Monitoring



Performance: *Energy Consumption*

- Safety
- Reliability
- Energy Use Intensity



Compliance: *Air Quality and Energy Efficiency*

- AHJ-ACH, Pressurization (NIH, AAALAC) BSL3
- Compounding Pharmacy – USP 800, FGI
- BEPP and other



Building Energy Performance Policy

THE CITY OF PHILADELPHIA
— OFFICE OF —
SUSTAINABILITY



Fault Detection - ASHRAE 36

- This guideline describes functional tests that, when performed, will confirm implementation of the sequences of operation.



ASHRAE Guideline 36-2021
(Supersedes ASHRAE Guideline 36-2018)
Includes ASHRAE addenda listed in Appendix C

High-Performance Sequences of Operation for HVAC Systems

Table 5.16.14.8 VAV AHU Fault Conditions

FC#1	Equation	$DSP_{AVG} < DSPSP - \epsilon_{DSP}$ and $VFDSPD \geq 99\% - \epsilon_{VFDSPD}$	Applies to OS #1 – #5
	Description	Duct static pressure is too low with fan at full speed	
	Possible Diagnosis	Problem with VFD Mechanical problem with fan Fan undersized SAT Setpoint too high (too much zone demand)	

Analytic Library

Eqpt	Alert Name	Description of Analysis	Built?	Date Built	Parameters	Tuned?	Vetted	Notes	Equip / Location	
AHUs	AC_ConstEna	AHU Fan running continuously	Yes	4/5/2022	FanSts = True for 36hrs	Yes	Yes	Currently for all fans	All AC Units	
AHUs	AC_FreqCycle	Fan turns on and off excessively.	Yes	7/22/2022	More than 6 sts COVs in 3 hrs	Yes	Yes	Currently for all fans	All AC Units	
AHUs	AC_SupplyFanHighSpeed	AHU fan at 100% for an extended time.	Yes	11/16/2021	SFan On, Spd >99% for 3.5 hr	Yes	Yes	added fallback to speed value (SDG) 1/19/22	All AC Units	
AHUs	AC_SupplyFanLowSpeed	AHU fan at 0% for an extended time.	Yes	11/17/2021	SFan On, Spd < 1% for 3 hr	Yes	Yes	added fallback to speed value (SDG 1/19/22)	All AC Units	
AHUs	AC_DatOutOfRange	AHU DAT off of setpoint for an extended time.	Yes	10/27/2021	+/- 3degF for more than 2 hr	Yes	Yes		All AC Units	
AHUs	AC_HighClgVlvPos	AHU cooling valve at 100% for an extended time.	Yes	10/20/2021	VlvPos > 99% for 3 hrs	Yes	Yes		S27: AC01, AC02, AC05, AC06 N6: AC07, AC09, AC11, AC12, AC13, AC14, AC15, AC16, AC19	
AHUs	AC_ClgVlvLeak	AHU cooling coil reducing the air temperature while the valve has been closed for an extended time.	Yes	10/27/2021	SFan On, Clg Vlv Closed, Dat - MAT > 3DegF for 2hr	Yes	Yes		S27: AC01, AC02, AC03, AC05, AC06 N6: AC07, AC09, AC10, AC11, AC12, AC13, AC14, AC15, AC16, AC19	
AHUs	AC_HighHtgVlvPos	AHU htg valve at 100% for an extended time.	Yes	10/20/2021	VlvPos > 99% for 3 hrs	Yes	Yes		S27: AC03 N6: AC07, AC09, AC10, AC15 Lobby Units	
AHUs	AC_HtgVlvLeak	AHU heating coil increasing the air temperature while the valve has been closed for an extended time.	Yes	11/2/2021	SFan On, Htg Vlv Closed, MAT - DAT > 3DegF for 2hr	Yes	Yes	revisit nodes boilers are only available for part of the year	S27: AC03 N6: AC07, AC09, AC10, AC15 Lobby Units	
AHUs	AC_SimulHtgClg	Heating and Cooling coil valves both open for an extended time.	Yes	11/17/2021	Both Valves >= 10% for 2 hrs	Yes	Yes	FAULT DETECTION AND DIAGNOSTICS		
								Faults	FDD Tool Analysis	
								General Faults		
AHUs	AC_HighPreheatTemp	AHU preheat coil increasing the air temperature while the valve has been closed for an extended time.	Yes	11/17/2021	SFan On, OA Below 55, Preheat Cls, Coil DA Hi Temp	Yes	Yes	revisit nodes	Schedules	Check if equipment is operating out of hours.
								is it a year	Manual override	Identify overrides that should not be in place.
Chillers	Chlr_HighSupTemp	Chilled water supply temperature significantly above setpoint for an extended time.	Yes	11/2/2021	CHW Supply Temp (average of three lines) > 46 for 1hr	Yes	Yes		Controllers	Compare controller output setpoints to the actual condition to find failed devices. Determine the stability of controllers.
Chillers	Chlr_LowSupplyTemp	Chilled water supply temperature significantly below setpoint for an extended time.	Yes	11/2/2021	CHW Supply Temp (average of three lines) < 40 for 1hr	Yes	Yes		Dampers	Identify if a damper is stuck open, closed, or at a fixed position, or leaking (i.e., compare mixed air temp to return air temp with outdoor air damper closed).
									Cooling/heating/precooling/preheating/reheating valve and coils	Identify if a valve is stuck or leaking. Identify a fouled or blocked coil. (i.e., a temperature difference exists across a coil when a valve is shut or not achieving a desired temperature drop across a coil when a valve is open.)
									Variable Air Volume (VAV) box faults	
									Sensors	Critical sensors: space temperature, relative humidity, carbon dioxide, airflow rate Detect if the sensor is outside of a feasible range, flat-lining, bias, drift, or failure.
									Thermostat occupied/unoccupied cooling/heating setpoints	Detect if the space cooling/heating setpoints deadband is not great enough (i.e., less than 3°F).

2024

BCxA

Table 1 – UC Open XP Specifications

21

Continuous Cx Tuning to Maintain Performance

- Fault Detection and Diagnostics
- Systems and Equipment
- Dashboards and Key Performance Indicators



Dashboards



kWh Comparisons									
2020		2021		2022		22 vs 21			
kWh Used	OAT	kWh Used	OAT	kWh Used	OAT	kWh Dif	OAT Dif		
Jan		2,029	0.0	2,231	37.0	Jan	9.96 %	nan °F	
Feb		1,950	0.0	1,757	40.8	Feb	-9.90 %	nan °F	
March		1,661	0.0	1,673	48.0	March	0.75 %	nan °F	
April		1,335	0.0	1,374	54.4	April	2.89 %	nan °F	
May		1,172	0.0	1,192	65.8	May	1.65 %	nan °F	
June		1,100	0.0	1,086	72.6	June	-1.24 %	nan °F	
July		1,127	79.9	1,169	79.1	July	3.73 %	-0.8 °F	
Aug		1,151	79.5	1,198	78.4	Aug	4.10 %	-1.1 °F	
Sept		1,061	72.6	1,079	70.0	Sept	1.69 %	-2.6 °F	
Oct	1,334	0.669	67.2	0.870	58.1	Oct	30.04 %	-9.1 °F	
Nov	1,434	1,334	51.0	1,379	52.8	Nov	3.40 %	1.8 °F	
Dec	1,925	1,607	49.3	0.140	43.9	Dec	-91.26 %	-5.4 °F	
Total	4,692		16,195		15,148	Total	-6.46 %	-17.2	

Commas, add total for year, & avg OAT

Floor Damper Summary									
West Dampers					East Dampers				
VAV	FPB	PIU	Web	Sum	VAV	FPB	PIU	Web	Sum
44.3 %	100 %	100 %	Web 12	Sum 25th	100 %	100 %	100 %	Web 11	Sum 24th
34.4 %	100 %	100 %	Web 11	Sum 23rd	100 %	100 %	100 %	Web 10	Sum 22nd
40.8 %	100 %	100 %	Web 10	Sum 21st	100 %	100 %	100 %	Web 9	Sum 20th
40.5 %	100 %	100 %	Web 9	Sum 19th	100 %	100 %	100 %	Web 8	Sum 18th
43.9 %	100 %	100 %	Web 8	Sum 17th	100 %	100 %	100 %	Web 7	Sum 16th
63.2 %	100 %	100 %	Web 7	Sum 15th	100 %	100 %	100 %	Web 6	Sum 14th
42.0 %	100 %	100 %	Web 6	Sum 13th	100 %	100 %	100 %	Web 5	Sum 12th
27.1 %	100 %	100 %	Web 5	Sum 11th	100 %	100 %	100 %	Web 4	Sum 10th
56.5 %	100 %	100 %	Web 4	Sum 9th	100 %	100 %	100 %	Web 3	Sum 8th
41.1 %	100 %	100 %	Web 3	Sum 7th	100 %	100 %	100 %	Web 2	Sum 6th
51.4 %	100 %	100 %	Web 2	Sum 5th	100 %	100 %	100 %	Web 1	Sum 4th
46.3 %	100 %	100 %	Web 1	Sum 3rd	100 %	100 %	100 %	Web 0	Sum 2nd
35.6 %	100 %	100 %	Web 0	Sum 1st	100 %	100 %	100 %	Web -1	Sum 0th

Sum	AC-03 PIUs	Link to Web-27 Charts
Sum	AC-05 VAVs	Link to Web-27 Charts
Sum	AC-06 FPB/VAV	Link to Web-27 Charts
Sum	AC-07 FPBs	Link to Web-24 Charts
Sum	AC-10 PIUs	Link to Web-24 Charts

PIU		PIU	
Dmper2	Dmper1	Dmper1	Dmper2
100.0 %	100.0 %	Web22 Sum 5th Web23	100.0 % 100.0 %
100.0 %	100.0 %	Web20 Sum 4th Web21	100.0 % 100.0 %
100.0 %	100.0 %	Web18 Sum 3rd Web19	100.0 % 100.0 %
100.0 %	100.0 %	Web16 Sum 2nd Web17	100.0 % 100.0 %
100.0 %	100.0 %	Web14 Sum 1st Web15	100.0 % 100.0 %




Methods to Implement

- Building Automation System + Add-On
- Building Automation System + 3rd Party Software
- Integration of Metering
- Procurement



MBCx Set Up & Maintenance

- Initial Checkout
- Continuous Tuning
- Integrated with CMMS



New Construction Cx: *Setting up for MBCx*

AIR HANDLING UNIT AUTOMATIC FAULT DETECTION AND DIAGNOSTICS

Client	Eqpt ID:	
Project	Type:	
Address	Model No.	
Location	Manuf.	

INSTRUCTIONS

Automatic Fault Detection and Diagnostics (AFDD):

The AFDD routines for the air handling units are continually assessing the air handling unit performance by comparing the values of the BAS inputs and outputs to potential fault conditions. The potential fault conditions is assessed at any point dependent upon the operating state (OS) of the air handling unit, as determined by the position of the cooling and heating valves and the economizer damper. There are five OS and they are as follows:

- OS 1: Heating
- OS 2: Free cooling, modulating outside air
- OS 3: Mechanical & economizer cooling
- OS 4: Mechanical cooling, minimum outside air
- OS 5: Unknown or dehumidification

OPERATING STATE 1 (HEATING)

FC#1: Duct static pressure too low with the fan at full speed


- | | | | |
|---|------------------------------|-----------------------------|------------------------------|
| 1. Decrease supply and return fans speed commensurately to the lowest possible speed (UOS) decrease supply and return fan speed to 15 Hz. | ☐ YES | ☐ NO | ☐ N/A |
| 2. Safely Open AHU doors on the downstream side of the supply side of the fan(s). | ☐ YES | ☐ NO | ☐ N/A |
| 3. Safely open AHU door on the suction side of the return side of the fan(s) | ☐ YES | ☐ NO | ☐ N/A |
| 4. Increase supply and return air fan speeds by increments of 15 Hz until supply fan is at 60 Hz. | ☐ YES | ☐ NO | ☐ N/A |



Commissioning: Day 1, Day 2, Day 100

- Baseline Functionality
- First-Year Tuning
- Performance Persistence

DOAS 3-1 FUNCTIONAL FORM	
Client	Unit Tag
Project	Location
Project No.	Date
Address	Performed By
GENERAL	
Pre-Requisite Documentation Contractor to make available as-built documentation as required by project specifications for commissioning provider to review. (red-lines acceptable)	
1. As built Documentation	No
MAINTENANCE VERIFICATION	
Maintenance Verification Verify preventive maintenance activities can be accomplished.	
1. All unit access doors are accessible	Yes
2. Filter is accessible	Yes
3. All dampers and actuators are accessible.	Yes
4. All fans motors and VFDs are accessible.	Yes



Practical Implementation

Work Order Details

5708639: MOB 6N WEST AHU OPERATION CK AHU00019

Task IDs						
Task ID	Description	Status	Measurement Point	Value	Date	Observations
5	ASSEMBLE OPEN/METERED STOCK MATERIALS:	COMP		0		
	NOTE: 1. Open Stock materials ARE NOT to be listed, unless shown on Materials tab of plan. 2. Metered materials (Truck Stock) must be listed on Work Order ONLY when NEW container is taken from storeroom. 3. Controlled items (on Materials tab) must ALWAYS be listed on Work Order. 4. When recording items on WO: Enter quantity TAKEN FROM STOREROOM Select from correct storeroom If item was NOT taken from a storeroom, enter as a NONSTOCK. This includes anything previously gotten out of storeroom and kept on truck or at another location. OPEN STOCK: ABS-1001 RAGS BOX SCOTT METERED MATERIALS: PNT-1001 PAINT, ZINC GALVANIZER 16 OZ SPRAY CAN OIL-1001 LUBE, DRV, SILICON AEROSOL #654-157 CHM-0002 ALGAECIDE, CONDENSATE TABLET #476-134 TOOLS: ME-005 VACUUM CLEANER, WET VAC					
10	ALWAYS WEAR PROPER PPE, AS DETAILED IN COMPANY GUIDELINES.	COMP		0		
15	MAKE REQUIRED CALLS & LOG. DO TAILBOARD BRIEFING.	COMP		0		
20	IF WORK WILL IMPACT "CUSTOMER", NOTIFY AFFECTED PERSONS OR AREAS.	COMP		0		
30	INSPECT OVERALL CONDITION OF CABINET AND DUCTWORK. LOOK FOR RUST/CORROSION, MISSING HARDWARE, DAMAGE OR HOLES, LEAKS, DAMAGED INSULATION	COMP		0		
40	INSPECT MOTOR, STARTER, CONTROLS, AND SELECTOR SWITCH FOR AUTO WARNING OR INDICATOR LIGHTS.	COMP		0		


STANDARD

ANSI/ASHRAE/ACCA Standard 180-2018
(Supersedes ANSI/ASHRAE/ACCA Standard 180-2012)

Standard Practice for Inspection and Maintenance of Commercial Building HVAC Systems

Maintain the Environment/Equipment on a Continuous Basis

	422	March Total	362		17	
K	MOB Equipment	K	MOB Alert Types	K	CSSB Equip	K CSSB Alert Type
12	AC09_PECO_MOB_N6_Web24	97	TU_SpaceTempOor4UnoccHtg	1	ERH_4_10_ERHs_PECO_ChristianSt	10 FCU_SpaceTempOor2OccClg
12	VAV23002_PECO_MOB_23_24_Web11	65	TU_SpaceTempOor3OccHtg	2	ERH_4_15_ERHs_PECO_ChristianSt	1 FCU_SpaceTempOor3OccHtg
11	AC03_PECO_MOB_S27	47	TU_SpaceTempOor2OccClg	1	ERH_4_6_ERHs_PECO_ChristianSt	6 RH_SpaceTempOor3OccHtg
9	AC10_PECO_MOB_N6_Web24	26	TU_DominantZoneDamper	2	ERH_4_7_ERHs_PECO_ChristianSt	
8	FPBN3025_PECO_MOB_N3W_Web18	20	TU_HighSpaceCO2	5	FCU_M_18_4_FCUs_PECO_ChristianSt	
7	VAV18004_PECO_MOB_17_18_Web8	19	AC_DatOutOfRange	1	FCU_M_19_1_FCUs_PECO_ChristianSt	
6	FPBN2001A_PECO_MOB_N2W_Web16	14	PIU_SpaceTempOor2OccClg	1	FCU_M_20_1_FCUs_PECO_ChristianSt	
6	FPBN2004_PECO_MOB_N2W_Web16	13	AC_HtgVlvLeak	2	FCU_M_21_1_FCUs_PECO_ChristianSt	
6	FPBN3008_PECO_MOB_N3W_Web18	9	EDH_SpaceTempOor3OccHtg	1	FCU_M_22_1_FCUs_PECO_ChristianSt	
6	PChwsTemp_T23_PECO_ChillPlant	8	PIU_SpaceTempOor3OccHtg	1	FCU_M_6_1_FCUs_PECO_ChristianSt	
6	VAV26013_PECO_MOB_25_26_Web12	7	AC_HighClgVlvPos	17		
5	AC05_PECO_MOB_S27	6	AC_ClgVlvLeak			
5	FPB08001_PECO_MOB_7_8_Web3	6	Chlr_HighSupTemp			
5	FPB09005_PECO_MOB_9_10_Web4	6	TU_DischargeTemp_HighLimit			
5	FPBN2001B_PECO_MOB_N2W_Web16	5	SlobbyHws_LowSupplyTemp			
5	SlobbyBBR_PECO_MOB_4_GS_Web1	3	TU_SpaceTempOor1UnoccClg			
5	VAV25005_PECO_MOB_25_26_Web12	2	AC_FreqCycle			
5	VAVSG005_PECO_MOB_NG_Web25	2	AC_HighHtgVlvPos			
4	AC01_PECO_MOB_S27	2	AC_SimulHtgClg			
4	AC11_PECO_MOB_N6_Web24	2	FCU_SpaceTempOor3OccHtg			
4	FPB08004_PECO_MOB_7_8_Web3	1	AC_SupplyFanHighSpeed			
4	FPB11002_PECO_MOB_11_12_Web5	1	PIU_SpaceTempOor1UnoccClg			
4	FPBN1037_PECO_MOB_N1W_Web14	1	TU_LowSpaceCO2			




Continuous Automated Testing

- Let's occupants focus on their work, not the building
- Reduces downtime
- Maintains a safe environment
- Saves \$\$



Monitoring-Based Commissioning

- High Performance Buildings
- Leverage Software
- Stakeholders
- Continuous Monitoring
- Flexibility in Program





Tenant Fitout Laboratory Commissioning

- Demand for Lab Space
- Work-from-Home
- Labs as Flexible Workspaces
- Landlord/Tenant Relationship



Lessons Learned: Tenant Fitout


- Landlord Coordination
- High Volume/Pressure HVAC
- Smart Monitoring for Reliability



TEST DATA	DESIGN	ACTUAL
TOTAL CFM (<i>Sum of VAV's</i>)	15,190	15,498
RETURN AIR CFM	11,990	12,324
OUTSIDE AIR CFM	3,200	3,174
TOTAL STATIC PRESSURE"	4.37"	4.42"
EXTERNAL STATIC PRESSURE"	3.00"	4.10"


Lessons Learned: Energy Recovery

- Simultaneous Heating/Cooling



Lessons Learned: HVAC Strategies


- Decouple
- Electrification



Standby Power Mode

7. Under standby utility power mode the supply fans shall be started and operated using the same sequence described above, up to a maximum of 25% of maximum AHU airflow – total of 5000 cfm (adj.). Airflow and fan speed control duct static pressure alarms shall be over ridden/suspended when operating under standby power mode.

Future of Monitoring-Based Commissioning





Questions?
Thank You!



Michael J. Dooley, PE, CCP, CEM, LEED AP